



TURA IKLİMLENDİRME VE SOĞUTMA SAN. TİC. A.Ş.

质量检验报告单

Product Quality Inspection Report

产品名称	二氟甲烷R-32	检验依据	AHRI700-2019
Product name		Inspection basis	
包装规格	STSU3410128	生产日期	2023-10-4
Packing specification		Product date	
产品等级	合同级	检验日期	2023-10-4
Product grade	Contract-class product	Inspection date	
产品批号	2023-10-07-29	产品数量	18000kg
Product batch No.		Product weight	
检测项目	单位	标准要求	检验结果
Inspection item	Unit	Requirement of standard	Inspection result
产品外观	/	无色透明液体，无可见 固体颗粒 Colorless transparent liquid, no solid particles	无色透明液体，无可见 固体颗粒 Colorless transparent liquid, no solid particles
Product appearance			
纯度，%	(m/m)	≥99.9	99.99
Purity ,%			
水分，%	(m/m)	≤0.001	0.00087
Moisture, %			
酸度(以 HCl 计),%	(m/m)	≤0.0001	<0.0001
Acidity(as HCl) ,%			
蒸发残留物，%	(m/m)	≤0.01	<0.01
Evaporating residue, %			
氯化物(以 Cl-计)试验	/	通过	通过
Chloride(content of Cl-)		pass	Pass
气相中不凝性气体，%	(v/v)@25°C	≤1.5	0.68
Non-condensable gas, %			
结论	本产品按 <u>AHRI700-2019</u> 标准检验，结果符合 <u>合同要求</u> ，产品等级为 <u>合同级</u> 。		
Conclusion	This product is verified according to the standard of <u>AHRI700-2019</u> , the test result meets the <u>Contract requirements</u> , product grade is <u>Contract-class product</u> .		
备注			
Remark			

检验 Inspected by: 马兆祥

复核 Reviewed by: 汪腊时

审核 Approved by: 颜光清