



TURA IKLİMLENDİRME VE SOĞUTMA SAN. TİC. A.Ş.

质量检验报告单

Product Quality Inspection Report

产品名称	R-404A	执行标准	AHRI700-2019
product name		Implementation standard	
包装规格	槽罐	生产日期	2023. 08. 24
Packing specification		Product date	
产品等级	合同级	检验日期	2023. 08. 24
Product grade	Contract-class product	Inspection date	
产品批号	202308212	产品数量	19.5T
Product batch No.		Product weight	
检测项目	单位	标准要求	检验结果
Inspection item	Unit	Requirement of standard	Inspection result
产品外观		无色，不浑浊，无异臭	无色，不浑浊，无异臭
Product appearance	/	Clear, Colorless, Odorless	Clear, Colorless, Odorless
纯度，%	(m/m)	≥99.9	99.98
Purity ,%			
水分，%	(m/m)	≤0.001	0.0008
Moisture, %			
酸度(以 HCl 计),%	(m/m)	≤0.0001	<0.0001
Acidity(as HCl) ,%			
蒸发残留物，%	(m/m)	≤0.01	0.0006
Evaporating residue, %			
氯化物(以 Cl ⁻ 计)试验	/	合格	合格
Chloride(content of Cl ⁻)		Qualified	Qualified
配比组成，%			
R143a/R125/R134a(52/ 44/4)	(m/m)	51.0-53.0/42.0-46.0/2.0-6.0	52.09/43.54/4.37
Refrigerant components, %			
气相中不凝性气体，%	(v/v)@25°C	≤1.5	0.8
Non-condensable gas, %			
结论	本产品按 <u>AHRI700-2019</u> 标准检验，结果符合 <u>合同要求</u> ，产品等级为 <u>合同级</u> 。		
Conclusion	This product is verified according to the standard of <u>AHRI700-2019</u> , the test result meets the <u>Contract requirements</u> , product grade is <u>Contract-class product</u> .		
备注	SIMU7088700		
Remark			

检验 Inspector: 李文文

复核 Reviewed by: 李杏梅

审核 Approval: 成国